



Entwicklungs- und Prüflabor
Holztechnologie GmbH
Zellescher Weg 24 · D-01217 Dresden
www.eph-dresden.de



DEUTSCHES
AKKREDITIERUNGSSYSTEM
PRÜFWESSEN GMBH
DAP-PL-1033.00



Test laboratory accredited by
Deutsches Akkreditierungssystem Prüfwesen GmbH
(German Accreditation System for Testing)
acc. to DIN EN ISO/IEC 17025



Recognized body of DIBt
and European Notified Body
for construction products (Number: 0766)

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-08-07-09-01

- Product:** Two-layer parquet with different wood species as top layer, lacquered
Dimension: (380 - 1200) mm x (65 - 120) mm x 10 mm
- Customer:** PT. Keramindo Megah Pertiwi
Jalan Raya Serang KM. 25
BALARAJA, TANGERANG 15610
INDONESIA
- Order:** Determination of selected properties for CE-Marking according to EN 14342
- Test methods:** Determination of the formaldehyde emission according to EN 717-1
Determination of the PCP content according to CEN/TR 14823
- Test report:** 276093

Test results:

Property	Result	Declaration according to EN 14342
Formaldehyde emission	0,01 ppm	Class E1
Content of PCP	not determinable	not to declare because the content is ≤ 5 ppm

Dresden, 9 July 2008

R. Eumacher

Head of laboratory



J. V. ...

Engineer in charge